

ΕΛΛΗΝΙΚΗ ΔΗΜΟΚΡΑΤΙΑ
ΥΠΟΥΡΓΕΙΟ ΔΙΚΑΙΟΣΥΝΗΣ
ΔΙΑΦΑΝΕΙΑΣ & ΑΝΘΡΩΠΙΝΩΝ
ΔΙΚΑΙΩΜΑΤΩΝ
ΕΛΕΓΚΤΙΚΟ ΣΥΝΕΔΡΙΟ
11^η ΥΠΗΡΕΣΙΑ ΕΠΙΤΡΟΠΟΥ
ΔΙΟΙΚΗΤΙΚΗΣ ΥΠΟΣΤΗΡΙΞΗΣ
ΤΜΗΜΑ Β΄

Ταχ. Διεύθυνση: Βουρνάζου 4 & Τσόχα
Ταχ. Κώδικας: 11521
Πληροφορίες: Άννα Κονταράτου
Τηλέφωνο : 2131309679
Fax : 213 1309680

ΑΝΑΡΤΗΤΕΑ ΣΤΟ ΔΙΑΔΙΚΤΥΟ
ΑΔΑ:

Αθήνα, 26/02/2018

Αριθμ. Πρωτ. 14201

ΑΠΟΦΑΣΗ

Θέμα: Απευθείας ανάθεση για την : «προμήθεια ενός (1) νέου FCU για την κάλυψη των αναγκών κλιματισμού στο χώρο του γραφείου της κας Προέδρου του Ελεγκτικού Συνεδρίου, στην Κεντρική Υπηρεσία του Ελεγκτικού Συνεδρίου»

Ο ΥΠΟΥΡΓΟΣ ΔΙΚΑΙΟΣΥΝΗΣ

Έχοντας λάβει υπόψη:

1. Τις διατάξεις:

- α). Του ν. 4270/2014 (ΦΕΚ 143^Α/28-6-2014) «Αρχές δημοσιονομικής διαχείρισης και εποπτείας (ενσωμάτωση της Οδηγίας 2011/85/ΕΕ)- δημόσιο λογιστικό και άλλες διατάξεις» όπως τροποποιήθηκε και ισχύει,
- β) του ν. 4412/2016 (ΦΕΚ 147^Α/8-8-2016) «Δημόσιες Συμβάσεις Έργων, Προμηθειών και Υπηρεσιών (προσαρμογή στις Οδηγίες 2014/24/ΕΕ και 2014/25/ΕΕ)»,
- γ) του Π.Δ 80/2016 (ΦΕΚ 145^Α /5-8-2016) «Ανάληψη Υποχρεώσεων από τους Διατάκτες»,

2. την υπ' αριθ.72923/29-10-2014(ΦΕΚ 2895Β), Απόφαση μεταβίβασης αρμοδιοτήτων του Υπουργού Δικαιοσύνης, όπως έχει τροποποιηθεί και ισχύει,

3. το Π.Δ. 125/2016 (ΦΕΚ Α 210), «Διορισμός Υπουργών, Αναπληρωτών Υπουργών και Υφυπουργών»,

4. την υπ' αριθ. αριθ. πρωτ. 14200 / 26 – 02 – 2018 Απόφαση Ανάληψης Υποχρέωσης, με ΑΔΑ: 7Θ41ΚΩ3 – ΟΤ1 ποσού **694,40 ευρώ**, σε βάρος της πίστωσης του προϋπολογισμού εξόδων «**Προμήθεια συσκευών θέρμανσης και κλιματισμού**», στον **ΚΑΕ 1712** , οικ. έτους 2017,

5. την από 09/11/2017 προσφορά της εταιρείας με δ.τ. «TRANE HELLAS SA», που αποτελεί αναπόσπαστο παράρτημα της παρούσας,

6. την ανάγκη προμήθειας ενός νέου FCU για την κάλυψη των αναγκών κλιματισμού στο χώρο του γραφείου της κας Προέδρου του Ελεγκτικού Συνεδρίου, στην Κεντρική Υπηρεσία του Ελ. Συν., επί των οδών Βουρνάζου 4 και Τσόχα στην Αθήνα.

Αποφασίζουμε

Την ανάθεση προμήθειας ενός νέου FCU για την κάλυψη των αναγκών κλιματισμού στο χώρο του γραφείου της κας Προέδρου του Ελεγκτικού Συνεδρίου, στην Κεντρική Υπηρεσία του Ελ. Συν., επί των οδών Βουρνάζου 4 και Τσόχα στην Αθήνα. στην Εταιρεία με δ.τ. «**TRANE HELLAS SA**», που εδρεύει στο Χαλάνδρι, επί της οδού Εριφύλης αρ. 18, με **ΑΦΜ 098032885**, Δ.Ο.Υ. ΦΑΕ ΑΘΗΝΩΝ, ΑΡ.Μ.Α.Ε 41221/01ΑΤ/Β/98/259, έναντι του ποσού των εξακοσίων ενενήντα τεσσάρων ευρώ και σαράντα λεπτά (**694,40 ευρώ**) συμπεριλαμβανομένου του ΦΠΑ.

Ο Υπουργός

ΣΤΑΥΡΟΣ ΚΟΝΤΟΝΗΣ

**PROPOSAL**

TRANE Commercial.

AIR CONDITIONING.

Technical characteristics**1) FVAS64-CXL1XWWTWEVWEX****General data**

Unit type
Unit size
Motor connection

FVAS64ACX*1X
64
STD

	Low	Medium	High
Total cooling capacity	4448 W	5594 W	7169 W
Sensible cooling capacity	3354 W	4291 W	5628 W
Total heating capacity	4292 W	5495 W	7202 W
Sound power level - Global	47.0 dB (A)	54.0 dB (A)	62.0 dB (A)
Sound pressure level	38.0 dB (A)	45.0 dB (A)	53.0 dB (A)
NR	31	39	48
NC	30	37	46
Air flow	735 m ³ /h	980 m ³ /h	1365 m ³ /h
Leaving air temperature - cooling	13.0 °C	13.7 °C	14.6 °C
Leaving air temperature - heating	40.4 °C	39.6 °C	38.6 °C
Electrical data	78 W	108 W	152 W
Water flow rate - cooling	0.21 L/s	0.27 L/s	0.33 L/s
Water flow rate - heating	0.21 L/s	0.27 L/s	0.33 L/s
Water pressure drop - cooling	9.0 kPa	13.5 kPa	20.9 kPa
Water pressure drop - heating	7.6 kPa	11.0 kPa	16.5 kPa

Cooling mode

Entering air temperature 27.0 °C
 Entering air temperature 19.0 °C
 Entering relative humidity 47 %
 Entering water temperature 7.0 °C
 Leaving water temperature 12.0 °C
 Glycol concentration 0 %

Heating mode

Entering air temperature 22.0 °C
 Entering water temperature 45.0 °C
 Leaving water temperature 12.0 °C

Physical data

Length (X) 1439 mm
 Width (Z) 255 mm
 Height (Y) 630 mm
 Weight 33 kg

**PROPOSAL**

TRANE Commercial.

AIR CONDITIONING.

2) FVAS64-DXL1XWWTWWVWFX**General data**

Unit type

FVAS64ADX*1X

Unit size

64

Motor connection

STD

	Low	Medium	High
Total cooling capacity	4448 W	5594 W	7169 W
Sensible cooling capacity	3354 W	4291 W	5628 W
Total heating capacity	3896 W	4745 W	5909 W
Sound power level - Global	47.0 dB (A)	54.0 dB (A)	62.0 dB (A)
Sound pressure level	38.0 dB (A)	45.0 dB (A)	53.0 dB (A)
NR	31	39	48
NC	30	37	46
Air flow	735 m ³ /h	980 m ³ /h	1365 m ³ /h
Leaving air temperature - cooling	13.0 °C	13.7 °C	14.6 °C
Leaving air temperature - heating	36.7 °C	35.1 °C	33.4 °C
Electrical data	78 W	108 W	152 W
Water flow rate - cooling	0.21 L/s	0.27 L/s	0.33 L/s
Water flow rate - heating	0.094 L/s	0.11 L/s	0.14 L/s
Water pressure drop - cooling	9.0 kPa	13.5 kPa	20.9 kPa
Water pressure drop - heating	5.8 kPa	8.2 kPa	12.1 kPa

Cooling mode

Entering air temperature

27.0 °C

Entering air temperature

19.0 °C

Entering relative humidity

47 %

Entering water temperature

7.0 °C

Leaving water temperature

12.0 °C

Glycol concentration

0 %

Heating mode

Entering air temperature

20.0 °C

Entering water temperature

70.0 °C

Leaving water temperature

60.0 °C

Physical data

Length (X)

1439 mm

Width (Z)

255 mm

Height (Y)

630 mm

Weight

35 kg



PROPOSAL

TRANE Commercial.

AIR CONDITIONING.

Price calculation

1) FVAS64*CXL1XWWTWEVWEX

Reference	Description	Qty	Price	Qty*Price
1	F Product family : Fan coil	1		
8	C Application type : 2 pipes cooling/heating (CCO)			
2	V Return air side : Vertical return			
4	S Fan Motor type : AC Motor			
12	X Filter type : Standard G0			
5	6 Unit casing size : 6			
6	4 Coil and Fan motor size : Size 4			
9	X Heating coil size : Standard / Without (2 pipe units)			
10	L Water connection side and control box : Water : Left, Control box : Right			
11	1 Fan speed selection : Standard speed			
13	W Electric heater : Without			
14	W Unit Controller type : Terminal block only	1		
15	T On board control interface (valve opposite side) : Unit mounted T-Type electronic thermostat	1		
17	E Water valve(s) : 3 way ON/OFF with micrometric valves kit	1		
18	V Drain pan/unit orientation : Vertical installation drain pan	1		
19	W Condensate pump : Without			
20	E Feet and return air grill : With factory mounted Feet	1		
Total Item (1) FVAS64		1		560 EUR

2) FVAS64*DXL1XWWTWWVWFX

Reference	Description	Qty	Price	Qty*Price
1	F Product family : Fan coil	1		
8	D Application type : 4 pipes - Cooling & Heating			
2	V Return air side : Vertical return			
4	S Fan Motor type : AC Motor			
12	X Filter type : Standard G0			
5	6 Unit casing size : 6			
6	4 Coil and Fan motor size : Size 4			
9	X Heating coil size : Standard / Without (2 pipe units)			
10	L Water connection side and control box : Water : RIGHT, Control box : LEFT			
11	1 Fan speed selection : Standard speed			
13	W Electric heater : Without			
14	W Unit Controller type : Terminal block only	1		
15	T On board control interface (valve opposite side) : Unit mounted T-Type electronic thermostat	1		
17	W Water valve(s) : Without			
18	V Drain pan/unit orientation : Vertical installation drain pan	1		
19	W Condensate pump : Without			
20	F Feet and return air grill : With factory mounted Feet and Return grill	1		
Total Item (2) FVAS64		1		470 EUR



PROPOSAL

TRANE Commercial.

AIR CONDITIONING.

Παρ' όλα αυτά, η παρούσα προσφορά βασίζεται στους παρακάτω ειδικούς όρους:

- Χρόνος παράδοσης:
 FVAS 2P: 20 εργάσιμες ημέρες στο εργοστάσιο και 1 εβδομάδα περίπου για την μεταφορά στο εργο.
 FVAS 4P: ετοιμοπαράδοτο (προσοχή: υδραυλικές συνδέσεις δεξιά, περιλαμβάνει τα accessories που φαίνονται παραπάνω.)
 Η παράδοση των μηχανημάτων είναι επί φορτηγού διεθνών μεταφορών στον τόπο του έργου. Σε περίπτωση ανάγκης μικρότερου φορτηγού, υπάρχει επιπλέον χρέωση που θα καθοριστεί κατόπιν συνεννόησης με το εργοστάσιο.
 Οι παραδόσεις γίνονται Δευτέρα έως Παρασκευή
- Τρόπος πληρωμής: κατόπιν συνεννόησης
- Η εγγύηση για τα προσφερόμενα μηχανήματα είναι 12 μήνες από την εκκίνηση ή 18 μήνες από την παράδοση, όποιο λήξει πρώτο.
- Οι παραπάνω τιμές δεν περιλαμβάνουν το νόμιμο ΦΠΑ του τιμολογίου
- Οι παραπάνω τιμές δεν περιλαμβάνουν τον νόμιμο φόρο ανακύκλωσης

ΕΓΚΡΙΝΕΤΑΙ

ΗΜΕΡΙΝΙΑ :

14.11.2017